

December 14, 2009

ACE ROTO-MOLD MFG., INC DEN HARTOG IND INC  
GREG DANKO  
4010 HWY 60 BLVD  
PO BOX 425  
HOSPERS IA 51238-0425

Re: Description: SEWAGE TANKS, POLYETHYLENE  
Manufacturer: ACE ROTO-MOLD MFG., INC  
Product Name: SEPTIC  
Model Number(s): AST-1500-1  
(52.75 L.L., 30" MAX. DEPTH OF BURY, G.P.D. 1500 WHEN USED AS A SEPTIC TANK  
BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; **TANK  
DIMENSIONS (ID) 134 IN. L X 59.5 IN W X 55.75 IN. H)**  
Product File No: 20090416

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of APRIL 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The inlet, outlet and tees must be schedule 40 PVC conforming to ASTM standard D2665 or D1785.
- The tees must be installed so that they extend a minimum six inches above the liquid level, nine inches below the liquid level but not more than 1/3 below the liquid level of the tank and have at least two inches of clearance between the top of the tee and the tank.
- The manhole riser on this product must terminate below grade within six inches of finished grade.
- The septic tank must be installed a minimum of eight but not more than thirty inches below final grade.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on 4/18/2005 under product file number #20050085. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050085.

**As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov